

Jeff Welton Sales Manager, Central USA Nautel



Episode #57



Mike Pappas

VP Business Development **Orban Labs**

Doing More with Less



Your questions please?

(if you don't see the control panel, click on the orange arrow icon to expand it)

Please enter your questions in the text box of the webinar control panel (remember to press send)



Remember: The completion of a Nautel webinar qualifies for ½ SBE re-certification credit, identified under Category I of the Re-certification Schedule for SBE Certifications.





AM Radio

- Outside of Spark-Gap and CW it's the oldest form of modulation
- Take a carrier and modulate it with audio!
- Simple and easy to implement and it's been on the air for 100 years

AM Modulation





AM Efficiency

- The downside to AM
 - Very inefficient to transmit
 - The AM carrier uses 66% of the transmitter power
 - Yet delivers no useful information!
 - Even with modern PWM AM transmitters the power consumption for a 50 kW AM station is substantial
 - So how do we make AM more efficient?



- This is referred to as Modulation Dependent Carrier Level (MDCL)
- There are two ways of achieving MDCL
 - DAM, which reduces the carrier level when audio is low
 - AMC, which maintains the carrier at maximum when no audio is present and reduces the carrier and the modulation together by up to 6 dB when modulation is at a maximum



AM MDCL DAM

- With DAM the carrier is decreased the most at moderate modulation levels
- Received loudness is increased when carrier is reduced
- The carrier is increased at higher modulation levels so that distortion does not occur
- As modulation density has substantially increased with modern audio processing the efficiency improvement with DAM is reduced



AM MDCL DAM Gain Function





AM MDCL AMC

- Carrier and modulation together are decreased with increasing audio modulation
- The carrier is increased to full power during quiet periods
 when noise is most easily perceived
- As modulation density has substantially increased with modern audio processing AMC can generate greater efficiency



AM MDCL AMC Gain Function





AM MDCL AMC Transmitter Block





AM MDCL AMC In The Field Testing

At the 0.5 mV/m location

| AM 100% Symmetrical Field Strength uV/m | dBm | AC Power kW | MDCL AMC 125% | Field Strength uV/m | dBm | Delta dBm | AC Power kW | Delta AC kW | Reduction in power consumption |
|---|--------|----------------|---------------------|---------------------------|--------|--------------|-------------------|----------------|--------------------------------------|
| 610 | -51.28 | 5.26 | 3 dB | 436 | -54.20 | -2.92 | 2.74 | -2.52 | -47.83% |
| | | | 4 dB | 386 | -55.28 | -4.00 | 2.21 | -3.05 | -57.98% |
| | | | 5 dB | 349 | -56.13 | -4.85 | 1.96 | -3.30 | -62.74% |
| | | | 6 dB | 325 | -56.75 | -5.47 | 1.18 | -4.08 | -77.51% |



AM MDCL AMC Testing Results

- Higher modulation density gives the MDCL system the ability to suppress the carrier to a much greater extent for longer periods of time
- At 6dB of AMC a 77% reduction in transmitter power consumption was observed
- Slight degradation in fringe coverage at AMC levels greater than 3 dB
- Townsquare & Bonneville are running 6 dB AMC on their stations that have transmitters that can do that with zero listener complaints since 2020 and significant power savings







Calculate your energy savings with Nautel's MDCL technology

Enter values into the green cells to estimate your savings.

Assumption: 30% savings in energy consumption when using MDCL

| | Select Modul | ation Density | | Mild | ~ | | |
|---------------------------------------|--------------|---------------|-----|-----------|---|--|--|
| | Current | NX Power | 3 🗸 | With MDCL | | | |
| Cost per kW/h (US cents) | 19 | 19 | | 19 | | | |
| Power of Transmitter in kW | 2.5 | 2.5 | | 2.5 | | | |
| Rated Efficiency | 73% | 73% | | 73% | | | |
| Modulation Factor | 1.1 | 1.1 | | 1.1 | | | |
| Consumption in kW/H | 3.8 | 3.4 | | 2.3 | | | |
| Hours of Operation / Day | 24 | 24 24 | | | | | |
| Days of Operation / Year | 365 | 365 | | 365 | | | |
| Total Yearly Consumption in kW/H | 33,000 | 29,378 | | 20,565 | | | |
| Total Transmitter Energy Cost (USD) | \$6,270 | \$5,582 | | \$3,907 | | | |
| Transmitter Power Savings / Year | | \$688 | | \$2,363 | | | |
| A/C Costs may add 10-15% | \$941 | \$837 | | \$586 | | | |
| Total Energy Cost | \$7,211 | \$6,419 | | \$4,493 | | | |
| Total Energy Savings | / Үеаг | \$791 | | \$2,717 | | | |
| Total Carbon Footprint Savings (Tons) | | 3 | | 11 | | | |



https://www.nautel.com/am-mdcl-savings/

| Consu | mption kWh | Consu | mption kWh | Difference kWh | n \$ Saving |
|--------|------------|--------|------------|----------------|-------------|
| Jul-15 | 44779.384 | Jul-16 | 23884.484 | 20894.9 | 1274.5889 |
| Aug-15 | 50750.622 | Aug-16 | 23580.889 | 27169.733 | 1657.353713 |
| Sep-15 | 35083.258 | Sep-16 | 21870.333 | 13212.925 | 805.988425 |
| Oct-15 | 32424.265 | Oct-16 | 21935.383 | 10488.882 | 639.821802 |
| Nov-15 | 28886.104 | Nov-16 | 20139.711 | 8746.393 | 533.529973 |
| Dec-15 | 30224.039 | Dec-16 | 20759.523 | 9464.516 | 577.335476 |
| Jan-16 | 29855.579 | Jan-17 | 19940.055 | 9915.524 | 604.846964 |
| Feb-16 | 31116.847 | Feb-17 | 20137.595 | 10979.252 | 669.734372 |
| Mar-16 | 33739.007 | Mar-17 | 22999.591 | 10739.416 | 655.104376 |
| Apr-16 | 35060.207 | Apr-17 | 23820.054 | 11240.153 | 685.649333 |
| May-16 | 38863.99 | May-17 | 23789.018 | 15074.972 | 919.573292 |
| Jun-16 | 33611.845 | Jun-17 | 24576 | 9035.845 | 551.186545 |
| | | | | | |

CJLI AM is running a Nautel NX50 at 50 kilowatt day and 20 kilowatt night

Totals 424395.147 267432.636 156962.511 9574.713171 Total Savings 36.98499196 % Less kWh

Touch Canada Broadcasting Limited Partnership owns CJCA AM in Edmonton, Alberta and CJLI AM in Calgary, Alberta. These are Touch Canada Broadcasting LP actual invoices comparison of kilowatt hours consumption from the previous year without running MDCL.

The NX50 ran for 13 months without MDCL running, before the feature was turned on. The NX50 has the MDCL feature built into the transmitter.

A field modification needed to be purchased for the XL60 transmitter. It cost us \$11,000 plus for the field modification kit. It took about six hours to install and set up FM12005 kit on the XL60. We are running AMC algorithm at 3dB compression at both sites. We pay 6.1 cents per kWh



| File J | Home Cut | Inse | rt Page Lay | - 11 - | A* A* = | Review | View | Help Wrap Tes | t | General | | - 💼 🖬 | | # # | 3 🖽 | ∑ AutoSur | * 47 | 0 | 4 | A Share | Comm | nents |
|--------|-------------|---------|-----------------------|------------|------------------|------------|-----------|------------------|----------|---------|----------|--|--------------------------------|------------|--------------|-----------------------|--------------------|--|-----------|-------------|----------|-------|
| ste 🕼 | Copy | | в <i>I</i> <u>U</u> - | · 🗠 - 🖽 - | <u></u> ≡ | | 1 II 🖾 | Merge & | Center - | \$ - 9 | 6 9 % | or Conditional Form Formatting ~ Tab | nat as Cell I le = Styles = | nsert Dele | le Format | € Fill ~ © Clear ~ | Sort & Filter • | Find & | Ideas | Secultivity | | |
| Clipt | board | | 6 | Font | - | | Alignment | | 5 | N | umber | fu Styles | | Cell | | | Editing | | Ideas | Sensitivity | | |
| | | | | Dir ID | | | | | | | | | | | | | | | | | | |
| | | | 5 X JR | DIFID | | | | | | | | | | | | | | | | | | |
| A | | 8 | C 0 | E | F | G | н | 1 | 1 | ĸ | L | M | N | 0 | P | Q | R | \$ | T | U | V | 1 |
| Dir ID | Re | NC ID | Point Nun Tx ID | Call Sign | Tx Freque I | Measuren R | adial I | Pattern | Initials | Note | Meas. Po | UTC Time | Local Time | Harmon | ic RF Source | e GPS Valid | Latitude | Longitude | Elevation | Fld Str 1 | Units 1 | Flds |
| | 0 | 0 | 72 | 3 KFXD | 630 | 630 | 227.6 | Dv . | стс | | 6 | 2019-09-15 19:30 | 2019-09-15 15:3 | 0 | 1 Loop An | t TRUE | 43,12608 | -115.451 | 1054 | 62.7 | dBuV/m | |
| | | | | | | | | | | | | | | | | | | | | | | |
| | 1 | 1 | 73 | 3 KFXD | 630 | 630 | 227.6 0 | Dy | CTC | | б | 2019-09-15 19:31 | 2019-09-15 13:3 | 1 | 1 Loop An | t TRUE | 43.12608 | -115.451 | 1055 | 62.6 | dBuV/m | _ |
| - | 2 | | 24 | 3 6500 | 630 | 620 | 227.6 | Dv | CTC | | 6 | 3019-09-15 19-31 | 2019-09-15 12-2 | 1 | 11000.00 | + TRUE | 43 13605 | .115.451 | 1054 | 67.0 | dBubtler | - |
| | - | | | 3 6740 | 050 | 030 | 22770 0 | 4 | cic | | 0 | 2013-03-13 13-31 | 2019-09-19 19:5 | | 1 0000 40 | L INVE | 43.12000 | -110/401 | 1004 | 02.0 | ubu v/m | |
| | 3 | 3 | 75 | 3 KFXD | 630 | 630 | 227.6 0 | Dy | CTC | | б | 2019-09-15 19:31 | 2019-09-15 13:3 | 1 | 1 Loop An | t TRUE | 43.12608 | -115.451 | 1055 | 62.6 | dBuV/m | |
| | | | | | | | | | | | | | | | | | | | | | | - |
| | 4 | 4 | 76 | 3 KFXD | 630 | 630 | 227.6 8 | Dy | CTC | | 6 | 2019-09-15 19:39 | 2019-09-15 13:3 | 9 | 1 Loop An | t TRUE | 43.12608 | -115.451 | 1055 | 62.8 | dBuV/m | - 1 |
| | 5 | 5 | 77 | 3 KFXD | 630 | 630 | 227.6 1 | Dy | CTC | | 6 | 2019-09-15 19:39 | 2019-09-15 13:3 | 9 | 1 Loop An | TRUE | 43.12608 | -115.451 | 1055 | 62.8 | dBuV/m | |
| | | | | | | | | | | | | | | | | | | | | | | |
| | 6 | 6 | 78 | 3 KFXD | 630 | 630 | 227.6 0 | Dy | CTC | | 6 | 2019-09-15 22:47 | 2019-09-15 16:4 | 7 | 1 Loop An | t TRUE | 44.34261 | -116.889 | 784 | 59.8 | dBuV/m | |
| | 7 | 2 | 79 | 3 KEYD | 630 | 610 | 227.6.1 | Def. | CTC | | 6 | 2010.00.15 22-49 | 2010-09-15 16-0 | 0 | 1 1000 40 | TRUE | A4 34350 | .116 889 | 785 | 60.1 | dBublin | |
| | 1 | | 13 | 3 107 40 | 030 | 030 | 227.00 | v1 | ere | | 0.1 | 2013-03-13 22:43 | 2013-03-13 104 | | 1 0000 411 | 1 INVE | 44.24233 | -110-003 | /65 | 00.1 | ubu v/m | |
| | 8 | 8 | 80 | 3 KFXD | 630 | 630 | 227.6 0 | Dy | CTC | | 6 | 2019-09-16 16:29 | 2019-09-16 10:2 | 9 | 1 Loop An | t TRUE | 43.51736 | -116.343 | 826 | 115 | dBuV/m | |
| | - | | | | | | | | | - | | | | | | | | | | | | - |
| | 9 | 9 | 81 | 3 KFXD | 630 | 630 | 227.6 | Dy | cic | | 0.++ | 2019-09-16 16:37 | 2019-09-16 10:3 | 7 | 1 Loop An | t TRUE | 43.51728 | -116.341 | 827 | 118.2 | dBuV/m | - |
| 1 | 10 | 10 | 82 | 3 KFXD | 630 | 630 | 227.6 0 | Dy | стс | | б | 2019-09-16 21:47 | 2019-09-16 15:4 | 7 | 1 Loop An | t TRUE | 43.51728 | -116.341 | 826 | 112 | dBuV/m | |
| | | | | | | | | | | | | | | | | | | | | | | |
| 2 | 11 | 11 | 83 | 3 KFXD | 630 | 630 | 227.6 0 | Dy | CTC | | 6 | 2019-09-16 22:59 | 2019-09-16 16:5 | 9 | 1 Loop An | t TRUE | 43.08714 | -115.609 | 953 | 61.8 | dBuV/m | |
| - | 12 | 12 | 84 | 3 KEXD | 630 | 630 | 227.6 | Dv | CTC | | 6 | 2019-09-16 23-21 | 2019-09-16 17-2 | 1 | 1 1000 40 | TRUE | 43,12608 | -115.451 | 1053 | 59.2 | dBuV/m | |
| | | | | a to the | 0.30 | 4.14 | aario i | <u>.</u> | | | A.2. | 011 07 10 13-14 | 1015 05 10 174 | - | a coop mit | - mys | 39.22000 | 110/4/1 | 1000 | 48-8 | addering | |
| | 13 | 13 | 85 | 3 KFXD | 630 | 630 | 227.6 | Dγ | стс | | 6 | 2019-09-16 23:35 | 2019-09-16 17:3 | 5 | 1 Loop An | t TRUE | 43.06798 | -115.441 | 977 | 55.5 | dBuV/m | |
| - | | | | 2.000 | | | | | | | | | | | | | | | - | | | |
| | 14 | 14 | 85 | 3 KPXD | 630 | 010 | 227.6 | W. | cic | | 0 | 2019-09-17 15:03 | 2019-09-1795 | 0 | 1 LOOD AN | TRUE | 43.06798 | -115,441 | 977 | 57.8 | disuv/m | |
| 1 | 15 | 15 | 87 | 3 KFXD | 630 | 630 | 227.6 0 | Dv | CTC | | 6 | 2019-09-17 15:25 | 2019-09-17 9:2 | 5 | 1 Loop An | t TRUE | 43.068 | -115.441 | 980 | 52.7 | dBuV/m | |
| | 2000 | Boise 1 | esting PI4100 0 | Data 18SEP | (+) | | | | | | | | 4 | | | | | and the second sec | | | | |

TUESDA



| B C D E F G H J K L M N D P Q R S T U V W X Y Z AA AB AC AD AE AF 1 Date Time V12 Unit V31 Unit A1 Unit A3 Unit P1 Q15/95/17 S15/75 V(A Q15/95/17 V12 Unit V13 Unit A1 Unit A3 Unit P1 Unit A3 Unit P1 V14 V14 Unit A1 Unit A3 Unit P1 V14 V14 V15 V14 V14< | |
|---|-------|
| Diste Time V12 Unit V31 Unit A1 Unit A3 Unit SSUM Unit SSUM Unit PSUM Unit V12 Unit <th< th=""><th>AG</th></th<> | AG |
| 2 2 010-05 1/2 0.06 0.078 KWH 0.078 KWH 0.071 KWH 0.021 KWH | Unit |
| 3 Date Time V12 Unit V13 Unit A1 Unit A2 Unit A3 Unit SISUM Unit SISUM Unit SISUM Unit PFGUMI Unit PFI Unit PFI Unit PFI Unit VIA Unit A1 Unit A2 Unit SISUM Unit SISUM Construction SISUM Unit SISUM Construction SISUM Unit SISUM Unit SISUM Construction SISUM Unit SISU ACA SISUM Construction SISUM Unit SISUM Unit SISUM Construction Construction SISUM Construction SISUM Construction SISUM Construction Construction SISUM Construction SISUM Construction | iO Hz |
| 4 2019-09-17 8:33-47 207.6 ACV 202.7 ACV 15.8 ACA 15.7 ACA 5.017 KW 5.724 KVA 2.755 KVAR 0.87 0.88 0.287 KWH 0.324 KVAH 0.161 KVARH 6C0 5 2019-09-17 8:33:55 207.5 ACV 2018.4 ACA 15.6 ACA 15.0 ACA 4.504 KVA 2.715 KVAR 0.88 0.287 KWH 0.336 KVAH 0.164 KVARH 6C0 7 2019-09-17 8:33:59 207.6 ACV 2018.4 ACA 15.67 ACA 4.551 KVA 2.628 KVAR 0.87 0.88 0.303 KWH 0.342 KVAH 0.17 KVARH 6C0 2019-09-17 8:34:07 207.5 ACV 206.5 ACV 15.61 ACA 15.95 ACA 4.509 KVA 2.668 KVAR 0.87 0.88 0.331 | Unit |
| 5 019.99-17 8:33:51 207.5 ACV 208.8 ACV 15.48 ACA 15.04 ACA 5.046 KW 5.732 KVA 0.28 0.292 KWH 0.38 VVAH 0.164 KVARH 6cc 6 2019.09-17 8:33:55 207.5 ACV 201.7 ACA 15.46 ACA 15.46 ACA 4.518 KW 5.458 KVA 0.88 0.297 KWH 0.38 KVAH 0.164 KVARH 6cc 7 2019.09-17 8:34:03 207.5 ACV 208.5 ACV 15.4 ACA 15.77 ACA 14.2 ACA 4.587 KW 5.458 KVA 2.627 KVAR 0.87 0.88 0.308 KWH 0.342 KVAH 0.175 KVARH 0.67 0.88 0.308 KWH 0.347 KVAR 0.87 0.88 0.308 KWH 0.327 KVAR 0.87 0.88 0.318 KWH 0.317 </td <td>iO Hz</td> | iO Hz |
| 6 0219-09-17 833:55 207.8 ACV 207.3 ACV 208.7 ACV 13.14 ACA 15.67 ACA 4.511 K/W 5.498 K/A 2.484 K/VAR 0.87 0.88 0.207 K/W 0.336 K/VAH 0.167 K/VARH 6C 7 2019-09-17 833:59 207.5 ACV 207.3 ACV 208.5 ACV 15.81 ACA 15.67 ACA 4.455 ACA 4.783 K/W 5.458 K/A 2.628 K/VAR 0.87 0.88 0.308 K/WH 0.342 K/VAH 0.167 K/VARH 6C 10 2019-09-17 834:15 207.5 ACV 208.6 ACV 15.61 ACA 15.91 ACA 4.591 K/W 2.669 K/VAR 0.87 0.88 0.331 K/WH 0.367 K/VAR 0.87 0.88 0.331 K/WH 0.167 K/VAR 16.61 ACA 14.57 ACA | iO Hz |
| 7 2019-09-17 8:33:59 207.6 ACV 207.2 ACV 208.5 ACV 15.1 ACA 14.55 ACA 4.783 KW 5.458 KVA 2.628 KVAR 0.87 0.88 0.303 KWH 0.342 KVAR 0.17 KVARH 6C 8 2019-09-17 8:34:03 207.5 ACV 2015.6 ACV 15.51 ACA 15.57 ACA 4.59 KW 5.374 KVAR 0.87 0.88 0.303 KWH 0.342 KVAH 0.17 KVARH 6C 10 2019-09-17 8:34:11 207.5 ACV 208.6 ACV 15.51 ACA 11.43 ACA 13.7 ACA 4.476 KW 5.085 KVA 2.421 KVAR 0.87 0.88 0.318 KWH 0.361 KVAH 0.17 KVARH 6C 12019-09-17 8:34:15 207.5 ACV 208.6 ACV 15.51 ACA 11.53 ACA 4.569 KW 5.275 KVAR 0.87 0.88 0.331 | iO Hz |
| 8 2019-09-17 8:34:03 207.5 ACV 207.3 ACV 208.6 ACV 14.84 ACA 15.77 ACA 14.2 ACA 4.689 KW 5.374 KVA 2.627 KVAR 0.87 0.88 0.308 KWH 0.349 KVAH 0.176 KVARH 6C 9 2019-09-17 8:34:07 207.5 ACV 207.6 ACX 15.61 ACA 15.34 ACA 4.476 KWA 2.627 KVAR 0.87 0.88 0.314 KWH 0.355 KVAH 0.176 KVARH 6C 10 2019-09-17 8:34:15 207.6 ACV 206.6 ACV 15.51 ACA 15.35 ACA 4.969 KW 5.676 KVA 2.757 KVAR 0.87 0.88 0.331 KWH 0.377 KVAH 0.181 KVARH 60 12 2019-09-17 8:34:19 207.5 ACV 207.2 ACV 12.08 | iO Hz |
| 3 2019-09-17 8:34:07 207.5 ACV 208.6 ACA 15.95 ACA 15.95 KVA 2.666 KVAR 0.87 0.88 0.314 KWH 0.355 KVAH 0.176 KVARH 6C 10 2019-09-17 8:34:11 207.5 ACV 208.5 ACV 15.61 ACA 15.7 ACA 13.7 ACA 4.476 KW 5.088 NA 2.421 KVAR 0.87 0.88 0.314 KWH 0.355 KVAH 0.175 KVARH 60 12 2019-09-17 8:34:19 207.5 ACV 208.6 ACV 15.64 ACA 14.57 ACA 14.57 ACA 4.595 KW 5.356 KVA 2.575 KVAR 0.87 0.88 0.33 KWH 0.357 KVAH 0.186 KVARH 60 12 2019-09-17 8:34:27 207.5 ACV 207.4 ACA 15.58 ACA 14.78 ACA 4.596 KW 5.356 KVA 0.87 0.88 0.335 KWH | iO Hz |
| 10 2019-09-17 8:34:11 207.5 ACV 208.5 ACV 15.6 ACA 14.34 ACA 13.7 ACA 4.476 KW 5.089 KVA 2.421 KVAR 0.87 0.88 0.319 KWH 0.361 KVAH 0.179 KVARH 6C0 11 2019-09-17 8:34:15 207.5 ACV 208.6 ACV 16.66 ACA 15.7 ACA 13.35 ACA 4.569 KW 5.356 KVA 2.755 KVAR 0.88 0.324 KWH 0.361 KVAH 0.182 KVARH 60 12 2019-09-17 8:34:12 207.5 ACV 208.6 ACV 15.8 ACA 14.69 KW 5.366 KVA 2.755 KVAR 0.88 0.338 KWH 0.337 KVAH 0.188 KVARH 60 14 2019-09-17 8:34:27 207.8 ACV 208.7 ACA 14.28 ACA 14.74 ACA 4.847 KW 5.458 KVAR 0.87 0.88 0.348 KWH | iO Hz |
| 11 2019-09-17 8:34:15 207.6 ACV 208.6 ACV 16.12 ACA 15.7 ACA 15.3 ACA 4.969 KW 5.676 KVAR 0.87 0.88 0.324 KWH 0.367 KVAH 0.182 KVARH 60 12 2019-09-17 8:34:19 207.5 ACV 208.6 ACV 15.6 ACA 13.55 ACA 4.996 KW 5.366 KVA 0.87 0.88 0.331 KWH 0.182 KVARH 60 12 2019-09-17 8:34:27 207.5 ACV 208.6 ACV 15.14 ACA 15.69 ACA 4.796 KW 5.486 KVA 0.87 0.88 0.335 KWH 0.385 KVAH 0.188 KVARH 60 15 2019-09-17 8:34:31 207.7 ACV 208.7 ACA 15.21 ACA 4.747 KW 5.428 KVA 2.628 KVAR 0.87 0.88 0.345 KWH 0.395 KVAH 0.191 KVARH 60 0.79 | iO Hz |
| 12 2019-09-17 8:34:19 207.5 ACV 208.6 ACV 16.66 ACA 14.67 ACA 13.35 ACA 4.696 KW 5.356 KVAR 0.87 0.88 0.33 KWH 0.373 KVAH 0.184 KVARH 60 13 2019-09-17 8:34:23 207.5 ACV 207.2 ACV 208.6 ACV 15.11 ACA 15.69 ACA 14.78 ACA 4.796 KW 5.488 KVA 2.666 KVAR 0.87 0.88 0.335 KWH 0.378 KVAH 0.184 KVARH 60 14 2019-09-17 8:34:27 207.8 ACV 207.1 ACA 15.12 ACA 14.28 ACA 14.79 KW 5.428 KVA 2.628 KVAR 0.87 0.88 0.34 KWH 0.395 KWAH 0.194 KVARH 60 15 2019-09-17 8:34:35 207.6 ACV 207.1 ACA 15.17 ACA 14.59 ACA 4.78 KW 5.627 KVAR | iO Hz |
| 13 2019-09-17 8:34:23 207.5 ACV 202.6 ACV 15.3 ACA 15.69 ACA 14.78 ACA 4.796 KW 5.488 KVA 2.666 KVAR 0.88 0.335 KWH 0.379 KVAH 0.188 KVARH 600 14 2019-09-17 8:34:27 207.8 ACV 2017.7 ACV 2018.8 ACA 14.28 ACA 15.21 ACA 4.747 KW 5.488 KVA 2.628 KVAR 0.87 0.88 0.346 KWH 0.391 KVAH 0.194 KVARH 60 16 2019-09-17 8:34:35 207.6 ACV 201.8 ACV 15.75 ACA 15.79 ACA 14.64 ACA 4.78 KW 2.625 KVAR 0.87 0.88 0.357 KWH 0.39 KVAH 0.197 KVARH 60 17 2019-09-17 8:34:34 2 | O Hz |
| 14 2019-09-17 8:34:27 207.8 ACV 207.2 ACV 15.4 ACA 14.7 ACA 4.81 KW 5.482 KVAR 0.87 0.88 0.34 KWH 0.385 KVAH 0.191 KVARH 60 15 2019-09-17 8:34:31 207.7 ACV 207.1 ACV 15.72 ACA 14.28 ACA 15.21 ACA 4.747 KW 5.482 KVAR 0.87 0.88 0.346 KWH 0.391 KVAH 0.191 KVARH 60 16 2019-09-17 8:34:35 207.6 ACV 207.8 ACV 15.75 ACA 15.71 ACA 14.44 ACA 4.78 KW 5.469 KVA 2.657 KVAR 0.87 0.88 0.357 KWH 0.396 KVAH 0.197 KVARH 60 17 2019-09-17 8:34:32 207.7 ACV 207.8 ACV 14.77 ACA 15.51 ACA 4.714 KW 5.461 KVAR 0.87 0.88 0.357 KWH | O Hz |
| 15 2019-09-17 8:34:31 207.7 ACV 207.1 ACV 208.8 ACV 15.7 ACA 14.28 ACA 15.21 ACA 4.747 KW 5.423 KVAR 0.87 0.88 0.346 KWH 0.391 KVAH 0.194 KVARH 60 16 2019-09-17 8:34:35 207.6 ACV 207.1 ACA 15.7 ACA 14.44 ACA 4.78 KW 5.469 KVAR 0.87 0.88 0.357 KWH 0.396 KVAH 0.194 KVARH 60 17 2019-09-17 8:34:34 207.7 ACV 207.3 ACV 15.85 ACA 15.21 ACA 4.738 KW 5.469 KVAR 0.87 0.88 0.357 KWH 0.49 KVARH 60 18 2019-09-17 8:34:43 207.7 ACV 207.3 ACV 14.71 ACA 15.63 ACA 14.39 ACA 4.704 KW 5.87 KVAR 0.87 0.88 0.357 KWH 0.41 KVAH | O Hz |
| 16 2019-09-17 8:34:35 207.6 ACV 207.1 ACV 208.9 ACV 15.7 ACA 14.64 ACA 4.78 KW 5.469 KVAR 0.87 0.88 0.35 KWH 0.396 KVAH 0.197 KVARH 60 17 2019-09-17 8:34:39 207.8 ACV 207.2 ACV 15.8 ACA 15.7 ACA 15.21 ACA 4.933 KW 5.614 KVAR 0.87 0.88 0.357 KWH 0.404 KVAH 0.2 KVARH 60 18 2019-09-17 8:34:43 207.7 ACV 208.7 ACV 14.77 ACA 15.8 ACA 14.3 ACA 4.714 KW 5.89 KVA 2.611 KVAR 0.87 0.88 0.357 KWH 0.44 KVAH 0.20 KVARH 60 19 2019-09-17 8:34:51 207.7 ACV 207.8 ACV 14.74 ACA 14.38 ACA 4.708 KW 5.28 KVAR 0.87 0.88 | O Hz |
| 17 2019-09-17 8:34:39 207.8 ACV 207.2 ACV 208.5 ACV 15.8 ACA 15.79 ACA 15.21 ACA 4.933 KW 5.614 KVAR 0.88 0.357 KWH 0.404 KVAH 0.2 KVARH 60 18 2019-09-17 8:34:43 207.7 ACV 207.8 ACV 14.77 ACA 15.85 ACA 14.3 ACA 4.714 KW 5.614 KVAR 0.87 0.88 0.357 KWH 0.44 KVAH 0.2 KVARH 60 18 2019-09-17 8:34:47 207.7 ACV 207.2 ACV 14.71 ACA 15.85 ACA 14.39 ACA 4.708 KW 5.839 KVA 2.611 KVAR 0.88 0.367 KWH 0.41 KVAH 0.20 KVARH 60 2019-09-17 8:34:51 207.7 ACV 207.8 ACV 16.44 ACA 16.18 ACA 16.09 ACA 5.104 KW 5.82 KVAR 0.87 | O Hz |
| 18 2019-09-17 8:34:43 207.7 ACV 207.3 ACV 14.7 ACA 15.8 ACA 14.3 ACA 4.714 KW 5.389 KVA 2.611 KVAR 0.88 0.362 KWH 0.41 KVAH 0.203 KVARH 60 13 2019-09-17 8:34:47 207.7 ACV 209.1 ACV 14.71 ACA 15.85 ACA 14.39 ACA 4.714 KW 5.389 KVA 2.611 KVAR 0.88 0.362 KWH 0.41 KVAH 0.203 KVARH 60 2019-09-17 8:34:47 207.7 ACV 207.8 ACV 14.4 ACA 15.8 ACA 4.708 KW 5.389 KVA 0.87 0.88 0.367 KWH 0.41 KVAH 0.206 KVARH 60 2019-09-17 8:34:55 207.7 ACV 207.8 ACV 16.4 ACA 16.18 ACA 15.8 ACA 4.94 KW 5.24 KVAR 0.87 0.88 0.373 KWH | O Hz |
| 13 2019-09-17 8:34:47 207.7 ACV 207.2 ACV 209.1 ACV 14.71 ACA 15.63 ACA 4.708 KW 5.372 KVA 2.588 KVAR 0.87 0.88 0.367 KWH 0.416 KVAH 0.206 KVARH 60 20 2019-09-17 8:34:51 207.7 ACV 208.9 ACV 16.44 ACA 16.09 ACA 5.104 KW 5.372 KVAR 0.87 0.88 0.337 KWH 0.426 KVAR 60 21 2019-09-17 8:34:55 207.6 ACV 208.7 ACV 16.05 ACA 15.58 ACA 4.98 KW 5.72 KVA 0.88 0.387 KWH 0.422 KVAH 0.206 KVARH 60 21 2019-09-17 8:34:59 207.6 ACV 208.7 ACA 15.58 ACA 15.32 ACA 4.98 KW 5.72 KVA 0.88 0.386 KWH 0.425 KVAH 0.212 KVARH 60 | O Hz |
| 20 2019-09-17 8:34:51 207.7 ACV 207.8 ACV 208.8 ACA 16.4 ACA 16.18 ACA 16.09 ACA 5.104 KW 5.842 KVAR 0.87 0.88 0.373 KWH 0.422 KVAH 0.209 KVARH 60 21 2019-09-17 8:34:55 207.6 ACV 207.7 ACV 208.7 ACV 16.08 ACA 15.58 ACA 4.98 KW 5.72 KVA 2.813 KVAR 0.88 0.378 KWH 0.422 KVAH 0.209 KVARH 60 22 2019-09-17 8:34:55 207.7 ACV 208.7 ACV 15.56 ACA 15.38 ACA 4.98 KW 5.72 KVA 2.813 KVAR 0.88 0.388 KWH 0.429 KVAH 0.209 KVAH 60 22 2019-09-17 8:34:55 207.7 ACV 208.7 ACA 15.58 ACA 15.28 ACA 5.02 KW 5.489 KVAR 0.87 0.88 | O Hz |
| 21 2019-09-17 8:34:55 207.6 ACV 208.7 ACV 16.08 ACA 15.58 ACA 4.98 KW 5.72 KVA 0.88 0.378 KWH 0.429 KVAH 0.212 KVARH 60 22 2019-09-17 8:34:55 207.7 ACV 208.7 ACV 15.76 ACA 16.85 ACA 15.32 ACA 5.02 KW 5.749 KVA 0.87 0.88 0.384 KWH 0.429 KVAH 0.212 KVARH 60 23 2019-09-17 8:35:03 207.8 ACV 207.4 ACA 15.04 ACA 15.58 ACA 15.32 ACA 5.02 KW 5.749 KVA 2.802 KVAR 0.88 0.384 KWH 0.425 KVAH 0.215 KVARH 60 23 2019-09-17 8:35:03 207.8 ACV 207.4 ACA 15.15 ACA 14.59 ACA 4.825 KW 5.489 KVAR 0.87 0.88 0.389 KWH 0.414 KVAH | O Hz |
| 22 2019-09-17 8:34:59 207.7 ACV 207.1 ACV 207.1 ACV 208.7 ACV 15.76 ACA 16.85 ACA 15.32 ACA 15.32 ACA 5.02 KW 5.749 KVA 2.802 KVAR 0.87 0.88 0.384 KWH 0.435 KVAH 0.215 KVARH 0.0215 KVARH | O Hz |
| 23 2019-09-17 8:35:03 207.8 ACV 207 ACV 208.9 ACV 15.04 ACA 16.15 ACA 14.59 ACA 4.825 KW 5.489 KVA 2.618 KVAR 0.87 0.88 0.389 KWH 0.441 KVAH 0.218 KVARH 60 | O Hz |
| | O Hz |
| 24 2019-09-17 8:35-07 207.6 ACV 207.1 ACV 208.8 ACV 14.91 ACA 16.52 ACA 14.5 ACA 4.849 KW 5.507 KVA 2.61 KVAR 0.88 0.88 0.395 KWH 0.447 KVAH 0.221 KVARH 60 | O Hz |
| 25 2019-09-17 8:35:11 207.7 ACV 206.9 ACV 208.9 ACV 15.23 ACA 15.79 ACA 14.58 ACA 4.791 KW 5.471 KVA 2.641 KVAR 0.87 0.88 0.4 KWH 0.454 KVAH 0.224 KVARH 60 | O Hz |
| 26 2019-09-17 8:35:15 207.8 ACV 207. ACV 208.8 ACV 15.87 ACA 15.87 ACA 15.37 ACA 4.94 KW 5.652 KVA 2.746 KVAR 0.87 0.88 0.406 KWH 0.46 KVAH 0.227 KVARH 60 | O Hz |
| 27 2019-09-17 8:35:19 207.8 ACV 207. ACV 208.8 ACV 15.76 ACA 17.75 ACA 15.21 ACA 5.126 KW 5.845 KVA 2.809 KVAR 0.87 0.88 0.411 KWH 0.466 KVAH 0.23 KVARH 60 | O Hz |
| 28 2019-09-17 8:35-23 207.8 ACV 207.3 ACV 208.7 ACV 14.29 ACA 15.2 ACA 13.83 ACA 4.552 KW 5.194 KVA 2.501 KVAR 0.87 0.88 0.416 KWH 0.472 KVAH 0.233 KVARH 60 | O Hz |
| 23 2019-09-17 8-35-27 207.7 ACV 207.3 ACV 208.5 ACV 16.35 ACA 15.86 ACA 15.72 ACA 5.044 KW 5.744 KVA 2.749 KVAR 0.87 0.88 0.422 KWH 0.478 KVAH 0.236 KVARH 6.0 | 0 Hz |
| 30 2019-09-17 8-35-31 207 6 ACV 207 1 ACV 208 8 ACV 15 5 ACA 16 38 ACA 14 92 ACA 4 924 KW 5 52 KVA 2 709 KVAR 0.87 0.88 0.427 KWH 0.485 KVAH 0.239 KVARH 60 | 0 Hz |
| 31 2019-09-17 8-35-35 207 6 ACV 207 1 ACV 208 7 ACV 16 6 ACA 15 96 ACA 15 14 ACA 5 114 KW 5 889 KVA 2 818 KVAR 0.87 0.88 0.433 KWH 0.491 KVAH 0.242 KVARH 60 | 0 Hz |
| 32 2019-09-17 8:35:39 207.6 ACV 207. ACV 208.5 ACV 15.89 ACA 16.32 ACA 15.31 ACA 4.993 KW 5.692 KVA 2.733 KVAR 0.87 0.88 0.439 KWH 0.498 KVAH 0.245 KVARH 60 | O Hz |
| 33 2019-09-17 8:35:43 207.6 ACV 207.1 ACV 208.6 ACV 15.86 ACA 16.07 ACA 15.34 ACA 4.974 KW 5.668 KVA 2.718 KVAR 0.87 0.87 0.474 KWH 0.504 KVAH 0.248 KVARH 60 | O Hz |
| 34 2019-09-17 8-35-47 207.6 ACV 207.1 ACV 208.6 ACV 15.64 ACA 15.9 ACA 14.97 ACA 4.873 KW 5.575 KVA 2.707 KVAR 0.87 0.88 0.45 KWH 0.51 KVAH 0.251 KVARH 60 | 0 Hz |
| 35 2019-09-17 8-35-51 207 5 ACV 207 2 ACV 208 5 ACV 16 43 ACA 15 27 ACA 15 27 ACA 4 947 KW 5 69 KVA 2 81 KVAR 0.86 0.88 0.455 KWH 0.516 KVAH 0.254 KVARH 60 | 0 Hz |
| 36 2019-09-17 8-35-55 207 6 ACV 207 2 ACV 208 7 ACV 15 54 ACA 15 6 ACA 14 96 ACA 4 834 KW 5 531 KVA 2 588 KVAR 0.87 0.88 0.461 KWH 0.523 KVAH 0.257 KVARH 60 | 0 Hz |
| 37 2019-09-17 8-35-59 207 6 4CV 207 4CV 208 7 4CV 16 12 4C4 15 76 4C4 15 55 4C4 5 099 KW 5 807 KV4 2 778 KV48 0.87 0.455 KWH 0.529 KV4H 0.25 KV48H 6 6 | 0 Hz |
| 38 2019-09-17 8-35-03 207.7 ACV 205.5 ACV 205.5 ACV 15.73 ACA 15.59 ACA 15.59 ACA 5.145 KW 5.832 KVA 2.745 KVAR 0.88 0.472 KWH 0.535 KVAH 0.253 KVAH 0.253 KVARH 5.0 | 0 Hz |
| | 0 Hz |
| | 9 Hz |
| 11 2019-09-17 8-35-15 207.4 ACV 207.5 ACV 15.79 ACA 15.12 ACA 15.5 ACA 5.6W 5.685 KVA 2.705 KVAR 0.87 0.88 0.488 KWH 0.575 KVAH 0.272 KVARH 0.575 KVARH 0.575 KVAR | O Hz |
| | 0 Hz |
| | 0 Hz |
| 141 2019-09-17 8-35-27 207 5 ACV 2008 ACV 14 55 ACA 15 54 ACA 14 21 ACA 14 21 ACA 14 21 ACA 15 51 KW 5 311 KVA 0.87 0.88 0.514 KWH 0.575 KVAH 0.291 KVARH 0.57 | 0 Hz |
| 45 2019-09-17 8-35-31 207 6 ACV 207 3 ACV 15 78 ACA 15 18 ACA 15 24 ACA 4 858 KW 5 54 KVA 2 644 KVAR 0.87 0.88 0.51 KWH 0.574 KVAH 0.284 KVARH 6.0 | |









Online Information



Webinars https://www.nautel.com/resources/webinars/



Nautel Waves Newsletter https://www.nautel.com/newsletters/



YouTube http://www.youtube.com/user/NautelLtd



Online Info, such as the Broadcasters' Desktop Resource https://www.thebdr.net/



THANK YOU!



